

CITY OF DAYTON SOURCE WATER PROTECTION PROGRAM CONFORMING USES – LIMITS ON REGULATED SUBSTANCES

A conforming use in a Well Field Protection District is limited to a maximum quantity of Regulated Substances as listed below in each of the four categories.

ROUTINE CATEGORY (R)

Regulated Substances associated with routine daily operations, including routine maintenance.

Conforming Use Limit: 160 pounds (20 gallons)



NON-ROUTINE MAINTENANCE CATEGORY (M)

Regulated Substances for the non-routine maintenance or repair of property.

Conforming Use Limit: 400 pounds (50 gallons)



CLEANING CATEGORY (C)

Regulated Substances which are cleaning agents, provided such cleaning agents are packaged for personal or household use, or are present in the same form and concentration as a product packaged for use by the general public. Cleaning agents containing chlorinated solvents are not excluded from reporting.

Conforming Use Limit: 1,600 pounds (200 gallons)



LABORATORY CATEGORY (L)

Regulated Substances for medical and research laboratory purposes, provided that the Regulated Substances are stored, handled or used in containers not to exceed five gallons (40 pounds) in size.

Conforming Use Limit: 2,000 pounds (250 gallons)

