



**TO:** Proposers on RFP No. 18039WTWE

**FROM:** City of Dayton, Ohio  
Division of Water Engineering

**SUBJECT: ADDENDUM NO. 01**

The City of Dayton has issued an Addendum to our RFP No. 18039WTWE.

Please consider this document in preparation of your proposal response. In the following Addendum, the City of Dayton shall be noted as "City".

To ensure the integrity of the proposal process, a signed copy of this proposal addendum notice shall be included with your company's response to this document.

\_\_\_\_\_  
(Print Name) (Date)

\_\_\_\_\_  
(Signature) (Company Name)

Sincerely,

*Kaitlyn Mueller*

Kaitlyn Mueller



**CITY OF DAYTON**  
**REQUEST FOR PROPOSAL (RFP) NO. 18039WTWE**  
**Design / Build Services for Storm Water Pumping Station Improvements**  
**November 2018**

In the following clarification, the City of Dayton shall be noted as “City”.

The following modifications shall be made to the RFP document:

**Section 1.02 RFP Schedule:**

The Due Date for Proposals has been revised to 2:00 PM local time on **December 13, 2018**.

An optional site visit has been scheduled for November 28, 2018. The Idylwild Pump Station will be open from 9am-10am and the Lucille Pump Station will be open from 10am-11am. Please RSVP to [kaitlyn.mueller@daytonohio.gov](mailto:kaitlyn.mueller@daytonohio.gov) if you plan to attend.

The last day to submit questions has been revised to 5:00 PM local time on November 30, 2018.

**Section 2.02 Background Information:**

Pictures from the Idylwild Pump Station and I-75 Embankment wall at the Lucille Pump Station are attached to this Addendum for your reference.

**Section 2.03 Scope of Work / Project Requirements:**

Delete current scope Item 6 and replace with, “6. Replace the bar screen.”

Revise the first sentence of scope Item 8 to the following, “Replace access door into wet well (hatchway) and replace surrounding railings.”

Revise the first sentence of scope Item 13 to the following, “Paint interior walls and ceiling of Pump House.”

Revise the first sentence of scope Item 17 to the following, “Replace wet well, interior and exterior lights with LED lights.”

Delete Item 18a and replace with, “Replace Bilco access doors at discharge chamber of southwest side of pump house.

- a. The replacement doors to match existing. The original design drawing and precast structure submittal are attached to Addendum No. 1”

### **Section 2.04 Pricing Structure:**

Replace the pricing worksheet with the attached revised worksheet.

### **The City has received two Questions in response to RFP 18039WTWE and offers the following clarifications:**

Q1. We are interested in bidding the submersible pumps on the Idylwild and Lucille projects. I don't see the requirements for the Idylwild pumps. Will the pumps be required to pass a 5" solid?

A1. The requirements of the Idylwild pumps have not been determined yet. It is the intention of this proposal to include both the development of the pump specifications and the procurement of the pumps to meet the new specification. For the purposes of the proposal, assume the pumps will be required to pass a 5" solid.

Q2. Is there flow data for the Idylwild Pumping Station?

A2. There are currently no flow meters at the Idylwild Pump Station. We will be able to review SCADA data to provide an estimated volume of water that was pumped through the station during a recent rain event. The SCADA data will be issued with Addendum No. 02.