



TO: Proposers on RFP No. 18039WTWE

FROM: City of Dayton, Ohio
Division of Water Engineering

SUBJECT: ADDENDUM NO. 02

The City of Dayton has issued an Addendum to our RFP No. 18039WTWE.

Please consider this document in preparation of your proposal response. In the following Addendum, the City of Dayton shall be noted as "City".

To ensure the integrity of the proposal process, a signed copy of this proposal addendum notice shall be included with your company's response to this document.

(Print Name) (Date)

(Signature) (Company Name)

Sincerely,

Kaitlyn Mueller

Kaitlyn Mueller



CITY OF DAYTON
REQUEST FOR PROPOSAL (RFP) NO. 18039WTWE
Design / Build Services for Storm Water Pumping Station Improvements
November 2018

In the following clarification, the City of Dayton shall be noted as “City”.

The following modifications shall be made to the RFP document:

Section 2.02 Background Information:

The Vectren Gas Facility Map and Easement Record Plan for the Idylwild Pumping Station are attached to this Addendum for your reference.

The City has received two Questions in response to RFP 18039WTWE and offers the following clarifications:

Q1. What is the required capacity for the proposed generator at Idylwild Pumping Station?

A1. The proposed generator must be able to power both pumps at the Idylwild Pumping Station in the event the station loses power.

Q2. Is there flow data for the Idylwild Pumping Station?

A2. There are currently no flow meters at the Idylwild Pump Station. We will be able to review SCADA data to provide an estimated volume of water that was pumped through the station during a recent rain event. The SCADA data will be issued with Addendum No. 03.

LAST DAY TO SUBMIT QUESTIONS IS FRIDAY, NOVEMBER 30th.