



August 14, 2020

TO: Bidders on I.F.B. No. 20035S
FROM: City of Dayton, Ohio
Division of Purchasing
SUBJECT: **Addendum No. 1 to above IFB**

The City of Dayton has received a question relating to our Invitation for Bid ("I.F.B.") No. 20035S.

The following are questions with answers for this I.F.B. Please consider this document in preparation of your bid response. In the answers of these questions the City of Dayton shall be noted as "City".

To ensure the integrity of the bid process, a signed copy of this addendum notice should be included with any bid offered to the City of Dayton as a result of IFB No. 20035S.

(Print Name)

(Date)

(Signature)

(Company Name)

Sincerely,

Jason Schortgen

Jason Schortgen



CITY OF DAYTON
INVITATION FOR BID (IFB) NO. 20035S
Vertiflo 720 Duplex Pump and Control System
August 2020

At this time, the City, Division of Procurement will not be accepting any additional questions regarding this solicitation. All bids submitted on or before the opening date and time will be considered for acceptance.

Question: What is the sump depth here. It says up to 26', do you want me to quote assuming a 26' depth?

Answer: The sump pump pit depth is 86 inches and the pump head is 26 feet.